



MCP 0.66/1.14kV Coal Mining Machine Shielded Rubber Flexible Cable

CABLE STRUCTURE:

Conductor:

Class 5 tinned copper

Insulation:

Power core: Polytetrafluoroethylene rubber (XJ-30)

Insulation shielding: Semiconductive tape

Ground core: Semiconductive rubber

(if used as a wrap, it is a semiconductive tape)

Control core: Polytetrafluoroethylene rubber (XJ-30)

Filling (optional):

Edge sealing rubber strips or glass fiber ropes

Sheath:

Chlorinated polyethylene or a mixture of other comparable materials (XH-03)

SPECIFICATION RANGE:

3 Core Power Main Core:

25 - 150 mm²

1 Core Ground Wire Core:

Refer to the structural parameter table

Control Core:

Minimum 2.5 mm² and not less than 3 cores

STANDARD:

MT 818.2-2009

APPLICATION:

Suitable for power connections of coal mining machines and similar equipment with a rated voltage not exceeding 0.66/1.14 kV.

TECHNICAL DATA:

Rated voltage:(U₀/U)

0.66/1.14 kV

The maximum system voltage:(Um)

1.1 times U

Temperature classification:

Maximum operating temperature of the conductor:

+75°C

Operating environment temperature:

-20°C to +45°C

Cable laying temperature: Not lower than 0°C (When the ambient temperature is below 0°C,

the cable should be preheated.)

Min.Bending Radius:

 $6 \times \text{cable O.D}$

Finished product voltage test:

Power wire core: 3.7 kV / 5 minutes Control wire core: 1.5 kV / 5 minutes

Installation method:

The laying of underground cables in coal mines is divided into methods such as in level tunnels or those below 45 °C, in chambers, and in vertical shafts or in tunnels above 45 °C or in boreholes.

CERTIFICATES:

Our series of mining products have undergone strict review by the National Coal Mine Safety Supervision Bureau and have obtained the Coal Mine Safety Mark Certification (MA Certification), providing a reliable guarantee for coal mine safety production.

















www.thcable.com

MCP 0.66/1.14kV Coal Mining Machine Shielded Rubber Flexible Cable

Specifications

MCP 0.66/1.44kV

Nom.Crosssection of conductor	Diameter of the power core conductor	Nominal thickness of the insulation for the power core wire	Nominal thickness of the sheath	Outer diameter of the cable	Total weight of the cable
N×mm2	mm	mm	mm	mm	kg/km
$3 \times 25 + 1 \times 6$	6.7	2.0	6.0	41.1	2751.5
$3 \times 35 + 1 \times 6$	7.9	2.0	6.0	44.2	3299.3
$3 \times 50 + 1 \times 10$	9.5	2.2	7.0	51.6	4663.0
3×70+1×16	11.2	2.2	7.0	56.3	5775.2
$3 \times 95 + 1 \times 25$	13.0	2.4	7.0	61.8	7132.1
$3\times120+1\times25$	14.7	2.6	7.0	66.9	8352.5
3 × 150+1 × 35	16.4	2.6	7.0	71.7	9855.0

Power Core Crosssection of conductor	Current carrying capacity	Maximum direct current resistance of the conductor at 20°C	Minimum insulation resistance at 20°C
mm2	A	Ω/km	MΩ·km
25	110	0.795	300
35	135	0.565	250
50	170	0.393	250
70	205	0.277	200
95	250	0.210	200
120	295	0.164	200
150	320	0.132	180
Control Core Crosssection of conductor		Maximum direct current resistance of the conductor at 20°C	Minimum insulation resistance at 20°C
mm2		Ω/km	MΩ·km
2.5		14.7	100
4		8.83	100
6		5.47	100
10		3.60	100

Email: tianhuan@thcable.com Phone Number: +86 311 66160316